



Central University of Tamil Nadu

Department of Education

Minutes of the Pre-Bid Meeting held on 22nd March 2018 at 11.00 am at Conference Hall, Administrative Block, Central University of Tamil Nadu, Thiruvavur.

The following members were attended the Pre-Bid meeting held on 22.03.2018

1. Prof. R. Karpaga Kumaravel, Professor & Head, Dept. of Education - Chairperson
2. Dr. P. Srinivasan, Associate Professor, Dept. of Education - Member
3. Dr. Biju, K., Assistant Professor, Dept. of Education - Member
4. Mr. A. Velu, Assistant Registrar - Purchase Nominee
5. Mr. Sunil Kumar, Assistant Professor, Dept. of Education - Member & Convener

The representatives of following prospective bidders attended the Pre Bid meeting:-

1. M/S GD LAB SOLUTIONS, Vadodara, Gujarat.
2. M/S MODERN LAB, Chennai.
3. M/S CORPORATE CONCEPTS, Chennai.
4. M/S MULTI LINK MARKETING INTERNATIONAL, Chennai.
5. M/S CITIZEN LAB, Bangalore.

Further, an email communication received from M/S MULTI LINK MARKETING INTERNATIONAL, Chennai with regard to pre- bid queries has been addressed by the Committee.

The attendance sheet is enclosed in Annexure- I.

Opening Remarks

The committee welcomed the participating members and after introduction, briefed all participants about the tender

The purpose of pre bid meeting is to explain the various important provisions of the bidding documents to the prospective bidders and to clarify the queries that the bidders may have in bidding documents.

The Technical queries and clarification sought by the prospective bidders are given as under:-

S.No	Query / Clarification Sought	Reply to the Query
1	Cylinder cabinet length in diagram was given as 1800mm whereas in specification it was 2700mm	Specification is correct. Amendment made in diagram of tender document for chemistry Lab
2	Wall storage cabinet length in diagram was given as 750 mm whereas in specification it was 1500 mm	Specification is correct. Amendments diagram of tender document for chemistry Lab
3	For all furniture 20 gauge was given. It was discussed 18 gauge is the universal standard.	Since 18 gauge is universal standard for furniture it was accepted and amended in tender document for Chemistry, Physics and Psychology Labs.
4	Drawer load capacity was not given	Drawer load capacity is 90Kg and amended in tender document for chemistry, Physics and Psychology Labs.

Pden
27/3/18

S. Kumar
27/3/18

27/3/18


1

RKMO
27/3/18


27/3/18


5	Shutter opening angle was not given	Shutter opening angle is 270 degree and amended in tender document for chemistry, Physics and Psychology Labs.
6	Wall storage of 6000 mm was given which is 20 feet	It is broken into 6 x 1000 mm and amended in tender document for chemistry and Physics Labs.
7	Exhaust fan width	It is given as 15 inch and amended in tender document for Chemistry and Physics Lab
8.	Request for Display of samples for Quality Evaluation Purpose	Request accepted, Amended a clause to display the samples by the bidder i.e. a modular box and a wall cabinet, on a stipulated date.

The tender document has also been refined. Repetitions has been removed. The amendments has been given in the Annexure II, the amendment are shown in red coloured font.


Dr. P. Srinivasan
 Member 27/02/18


Dr. Biju, K
 Member


Mr. A. Velu
 Purchase Nominee


Mr. Sunil Kumar
 Member & Convener


Prof. R. Karpaga Kumaravel
 Chairperson