



तमिलनाडुकेन्द्रीयविश्वविद्यालय

(संसदद्वारापारितअधिनियम 2009 केअंतर्गतस्थापित)

CENTRAL UNIVERSITY OF TAMIL NADU

(Established by an Act of Parliament, 2009)

नीलक्कुडीपरिसर/Neelakudi

Campus, कंगलान्चेरी/Kangalancherry, तिरुवारूर/Thiruvārūr- 610 005

Estate Section

estate@cutn.ac.in

04366 277 466

CUTN/ENGG/CVL/Tender/2021-22/10

26.11.2021

Name of work	:	Providing & Installation, Testing, Commissioning, etc., of RO plants 250 LPH at Academic and Hostel Buildings, Central University of Tamil Nadu, Thiruvārūr.
Tender Ref No	:	CUTN/ENGG/CVL/Tender/2021-22/10
Pre Bid meeting Date & Time	:	22.11.2021 at 15.30 Hrs.

Minutes recorded at the Pre bid meeting for "Providing & Installation, Testing, Commissioning, etc., of RO plants 250 LPH at Academic and Hostel Buildings, Central University of Tamil Nadu, Thiruvārūr.

Sl. No	Clarification Sought	Reply to the Clarification
1	What is the quality (i.e. Class, pipe wall thickness) of CPVC pipe lines as mentioned in tender document page no: 42 of 43 Sl. No: 09	Class -I,SDR-11
2	What is the type of power supply to be provided in RO plant (i.e Single Phase or Three Phase)	Single Phase
3	If any warranty period for RO Plants?	Yes, 12 month from the date of handing over of RO plants to CUTN. Warranty will be covered for all Equipments /filters etc. (i.e Replacing of membrane, filters, etc) .Additional amount will not be provided by CUTN for any replacement of membrane, filters and repair/replacement (if any) equipment like motors, etc during warranty period.
4	Whether test certificates have to be submitted after installation & commissioning?	Yes, test certificates should be submitted to CUTN after installation & commissioning of RO plants as per WHO guidelines and BIS standards.
5	Whether the available raw water TDS (mg/l) limit can be provided (approximately)?	Yes, 780(mg/l).

6	Whether the CPVC pipe lines have to be laid from Plant to collecting point by internal or external portion?	Through external portion only (including scaffolding charges, etc).
7	Whether Solenoid valves have to be provided or not?	Yes, solenoid valves should be provided in all RO plants.
8	Whether payment will be made on part payment?	Payment will be made on submission of final bill on satisfactory completion, handing over of plants to CUTN along with Installation report and RO water TDS level report.

This is issued with the approval of committee and competent authorities of University.



(Handwritten Signature)

Executive Engineer, CUTN
Thiruvavur

कार्यकारी अभियंता (सिविल)
Executive Engineer (Civil)
तमिलनाडु केन्द्रीय विश्वविद्यालय
Central University of Tamil Nadu
तिरुवावूर/Thiruvavur-610 005