



தமிழ்நாடு கेंद्रीय विश्वविद्यालय
(संसदद्वारा पारित अधिनियम 2009 के अंतर्गत स्थापित)
CENTRAL UNIVERSITY OF TAMIL NADU
(Established by an Act of Parliament, 2009)

नीलकुडी परिसर/Neelakudi
Campus, कंगलान्चेरी/Kangalancherry, तिरुवारूर/Thiruvarur- 610 005
Estate Section
estate@cutn.ac.in 04366 277 466

CUTN/Estate/CVL/Tender/2022-23/14

28.02.2023

Subject	: Clarifications of Pre Bid meeting
Tender Ref No	: CUTN/ENGG/CVL/Tender/2022-23/14
Name of work	: Construction of 150 KLD (1 No) Capacity Sewage Treatment Plants (STP) using MBBR technology including plant Operation for One year at Central University of Tamil Nadu, Thiruvarur.
Value of Work	: Rs.72,38,130/-

Minutes recorded at the Pre bid meeting for “Construction of 150 KLD (1 No) Capacity Sewage Treatment Plants (STP) using MBBR technology including plant Operation for One year at Central University of Tamil Nadu, Thiruvarur” held on 24.02.2023 at Admin Block, CUTN, Thiruvarur.

Sl. No.	Queries/Clarifications/Doubts Sought by bidders	Response from CUTN
Queries from M/s. Ariake Bio-Tech Solutions Pvt., Ltd., Chennai		
1	Request to add any other equivalent to MBBR technology suitable for sewage treatment like Eco Bio block Technology.	Please refer Pg. No. 17 of 52 in the tender document (under Moving Bed Bio Reactors clause)
2	Request to reduce EMD value 2% to 1%	Please refer Pg. No. 05 of 52 in the tender document (under Earnest Money Deposit (EMD) Clause)
3	Request to increase the work contract/ construction period 03 months to 05 months.	Please refer Pg. No. 02 of 52 in the tender document (Under Contract period clause.)
4	Requested to time extending of last date and time of submission of tender document 01.03.2023 to 15.03.2023.	No extension.
5	In the tender, Anoxie tank is included in the design unless nitrogen and phosphorus level is very high, anoxie tank will not be included in the design. Otherwise if there two items are within the allowable standerd, anoxie tank is not suggested by TNPCB. Hence it may be removed from the design.	Noted.
6	Payment terms may be considered as below 5% mobilization advance.	Please refer Pg. No. 07 of 52 in the tender document (Under Payment clause.)
7	We will be executing the contract in the name of our parent company Ariake	Please refer Pg. No. 03 & 04 of 52 in the tender document (Under Eligibility criteria

	BioTech Solution Pvt. Ltd., However the project done by our company S.R. Environ Pvt. Ltd., may also be considered for eligibility	clause.)
8	The eligibility criteria is fixed as 39.16 Lakh average in the last 3 years. Due to lockdown there was almost "Nil" business allowing 2020, 2021 and part of 2022. Hence the value what we have done in 2022-23 may be considered we will produce a professional balance sheet for the year 2022-23.	As per tender document.
9	Will the structure drawing be provided by the University	The structural drawing shall be prepared by successful bidders and be vetted by Registered structural Engineer (Consultant charges will be borne by Successful bidder).
10	Is there a brand restriction for cement and steel to be used. If so please provide the brand details.	Corrigendum will be published in the website.
Queries from M/s. Espure Water Solution Pvt., Ltd., Chennai.		
1	No queries	
Email Queries from M/s. Ensys Technologies (India) Pvt., Ltd.,		
1	Need dimensions of collection tank.	10m x 6m x 3.5m
Email Queries from M/s. Clear Aqua Technologies Pvt., Ltd.,		
1	The time schedule for completing within 3 months given by you is not sufficient which we requires about 6 months for the completion. Meanwhile we can offer Prefabricated FRP on ground tank with minimum 20 years life span and we can complete the work within 3 months as you scheduled.	Please refer Pg. No. 02 of 52 in the tender document (Under Contract period) clause.
2	In the tender document, design calculations are not mentioned and understanding the design criteria which is very important to provide the proper operation. And if possible please mention the inlet and outlet sewage characteristics.	The structural drawing shall be prepared by successful bidders and be vetted by Registered structural Engineer (Consultant charges will be borne by Successful bidder).
3	It was mentioned that make of some equipments by some OEM's name and we can offer with our own make.	Corrigendum will be published in the website.



11/25/02/2023
 Executive Engineer (Civil)
 कार्याकारी आयुक्त (सिविल)
 Executive Engineer (Civil)
 तमिलनाडु केन्द्रीय विश्वविद्यालय
 Central University of Tamil Nadu
 तिरुवारूर/Thiruvannur-610 005